


NOTE
PUMP RUNNING PRESSURE
SWITCH TO BE INSTALLED
IN THE PUMP DELIVERY
PIPEWORK BEFORE THE
NON RETURN VALVE.

NOTE *
CT NOT FITTED TO
THESE STARTERS
5.5-18.5kW 415V,
5.5-18.5kW 380V.

DRAWING COVERS
5.5-160kW 415V
5.5-90kW 380V,

NOTE:
□ = SWITCH LOOM
○ = INDICATOR LOOM
△ = INTERLOCK



REV	Register No.	Revision Details	SIG & DATE
4	Windchill	PUMP INHIBIT CONTACT CHANGED	NI 09.07.13
3	Windchill	COMPANY ADDRESS UPDATE	DG 27.03.13
2	R39070	REVISE LAYOUT OF DRAWING: CONNECTIONS LAYOUT	DG 30.07.09
1	R37462	FIRST ISSUE: MK3D STAR DELTA STARTER SCHEMATIC	DG 25.01.08

	DRN	DCa	05.10.06	COMPLETE UNIT					
	CHK	WR	05.10.06	MK3 D STAR DELTA ELECTRIC					
	APP'D	SS	25.01.08	STARTER EN 12845					
	Drawn scale: NTS Original W/O No.N/A			DESCRIPTION CIRCUIT SCHEMATIC					
SPP PUMPS LTD. TEL +44 (0)1594 832701 CRUCIBLE CLOSE, MUSHET INDUSTRIAL PARK, COLEFORD, GLOUCESTERSHIRE, ENGLAND GL16 8PS				FileName	FW500D-EN.Dwg	Border Size	A3		
				DRAWING NUMBER			FW500D-EN		