

Österreichische Vereinigung für das Gas- und Wasserfach A-1010 Wien, Schubertring 14

Telefon: +43/1/5131588-0* / Telefax: +43/1/5131588-25 E-Mail: office@ovgw.at / Internet: www.ovgw.at

Accredited by the Federal Ministry for Digital, Business and Enterprise of the Republic of Austria



ÖVGW Certificate

of the conferment of the right to use the ÖVGW Quality Mark for Water

Registration number

W 1.565

Period of validity

until the end of October 2023

Owner

Distribution in Austria

E. Hawle Armaturenwerke GmbH

Wagrainerstraße 13 4840 Vöcklabruck

Manufacturer

E. Hawle Armaturenwerke GmbH / AT

Type of test

Renewal test

Test report

TGM - VA HL 8973 dated 23 September 2021

Quality standards / Testing directives

 QS-W 503 version January 2021 in combination with ÖNORM standards EN 14525 and EN 14901 as well as QS-W 100 version May 2020 and QS-W 200 version May 2020 Product

Wide-tolerance coupling and flange adapters

HAWLE-SYNOFLEX™

for the drinking water supply system

flexible and traction-secured fittings made of ductile cast iron with epoxy resin powder coating for connecting pipes made of polyethylene (PE), polyvinylchloride (PVC), steel, cast and asbestos cement (not secured against traction):

Type: 7974 connector and reducing connector (sleeve to sleeve) with the dimensions DN 40, 50, 65, 80, 100, 125, 150, 200, 225, 250, 300; PFA 16 bar DN 350, 400; PFA 10 bar

Type: 7994 flange and reducing flange (flange to sleeve) with the dimensions DN 50, 65, 80, 100, 125, 150, 200, 225, 250, 300; PFA 16 bar DN 350, 400; PFA 10 bar

Type: 7980 end cap with or without 2" outlet (sleeve) with the dimensions DN 50, 65, 80, 100, 125, 150, 200, 225, 250, 300; PFA 16 bar DN 350, 400; PFA 10 bar

Type: 7981 duckfoot bend (flange to sleeve) with the dimensions DN 80, 100; PFA 16 bar

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products "Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

ZVR 818158001