



Accredited by the Federal Ministry
for Digital, Business and Enterprise of the Republic of Austria



ÖVGW Certificate

of the conferment of the right to use
the ÖVGW Quality Mark for Water

Registration number

W 1.845

Period of validity

until the end of February 2024

Owner ♦ Distribution in Austria

E. Hawle Armaturenwerke GmbH
Wagrainerstraße 13
4840 Vöcklabruck

Manufacturer

ÖZ-KAN MAKINA ELM. SAN. ve TIC. A.S. / TR

Type of test

Initial Test

Test report

1900356/2 dated 8 February 2021

Quality standards / Testing directives

- QS-W 501/1 version December 2014
in combination with ÖNORM standard
EN 1074-4

Product

Aeration and ventilation valves

Type: 9842K

Range of application:

Above-ground installation

Operating range:

- PN 10: 0,5 bar through 10 bar
- PN 16: 0,5 bar through 16 bar
- PN 25: 0,5 bar through 25 bar

Nominal widths and pressures:

- PN 10: DN 50, 80, 100, 150, 200, 250
- PN 16: DN 50, 80, 100, 150, 200, 250 and 300
- PN 25: DN 50, 80, 100 and 150

ZVR 818158001

The conferment is based on the General Terms and Conditions GW 30 ÖVGW Quality Mark for Gas & Water Products
"Conditions for the award of the ÖVGW Quality Mark for gas and water supply products."

Vienna, 19 February 2021

Dipl.-Ing. (FH) Alexander Schwanzer
Head of the ÖVGW Certification Office